


OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
RWS&S SUB-DIVISION, BHANJANAGAR, GANJAM

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Sri Nihar Ranjan Swain, Assistant Executive Engineer RWS&S Sub-Division, Bhanjanagar has inspected the St. Xavier's High School, Bhanjanagar, Ghumusur, Ganjam on 1st April 2023 and found that the St. Xavier's High School has safe drinking water facilities for the students and members of staffs of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the central/ state/U.T Govt.

The above is valid for a period of one year from the date of issue the certificate. The Test Report is as follow:

Sl. No	Characteristics	Test Result	Acceptable
1	Turbidity	1.0	1.0
2	Colour(unit on platinum cobalt scale)	3.0	5.0
3	PH (Hydrogen Potential)	7.0	7.0 to 8.5
4	Iron (as Fe) (mg/l)	0.1	0.1
5	Residual Chlorine(mg/l)	0.2	0.2 to 0.1


1/4/2023
Asst. Executive Engineer
RWS&S Sub-Division
Bhanjanagar



Goutarajai Parida .
Secretary
Xavier's Educational Trust
Bhanjanagar, Ganjam, Odisha